

INSPECTION CERTIFICATE

Certificate No.: 2114473844-2026/001

Name and address of bearer/
manufacturer:

INKA YAPI BAĞLANTI ELEMANLARI SAN. VE TİC. A.Ş.
İstanbul Anadolu Yakası OSB. Gazi Bulvarı No:7
Tuzla / İSTANBUL

We hereby certify that according to the results of the inspection, the product mentioned below fulfills the contractual requirements governing mission entrusted to TÜV NORD Turkey.

Product is marked with hard stamp ☐ Yes ☒ No: TÜV NORD Turkey hard stamp on the nameplate

Inspected according to

ANSI ASHRAE 171-2017

Description of product:

Seismic Cable Set

ISH25 ISHR35

Model & Type:

ISHR25 ISH50

ISH35 ISHR50

Inspection Report No:

FRP-TUVNORD-26/1396-R00

Inspection date or period:

07-08.06.2026

Place of manufacture:

İstanbul Anadolu Yakası OSB. Gazi Bulvarı No:7
Tuzla / İSTANBUL

Inspected by:

Özgün Ozan TÜRK

This Test Certificate has been granted to the applicant based on reviewing of the test results reported in the Test Report which was issued by the manufacturer's laboratory under the supervision of a TÜV NORD expert upon request of the manufacturer/certificate holder.

An Inspection/audit based on factory production control system was not performed the manufacturer's premises. These test results are not covered by the scope of accreditation

Istanbul , 10.08.2026

Certifier for Product of TÜV NORD
Turkey Teknik Kontrol ve Belgelendirme

A.Ş.

MEHMET SELÇUK

TÜVNORD

TÜV NORD Turkey Teknik Kontrol ve
Belgelendirme A.Ş.
Şehit Mehmet Fatih Öngül Sokak, No: 5
Kat: 4 Odak Plaza, Kozyatağı, 34742
Kadıköy/İSTANBUL

Tel. +90-(0) 216 361 29 95
Fax +90-(0) 216 380 67 87
e-mail tuv-nord@tuv-turkey.com

ANNEX I

Certificate No.: 2114473844-2026/001

TEST DATA							
MODEL CODE	Diameter (mm)	Rope Production	Colour	Failure Load (kgf)	Safety Factor	Maximum Allowable Design Load (kgf)	Type of Failure
ISH25	2.50	Pre-streching	Blue	348.94	1.5	232.63	Rope Breakage
ISHR25	2.50	Pre-streching	Blue	363.21	1.5	242.14	Rope Breakage
ISH35	3.50	Pre-streching	Orange	800.00	1.5	533.33	Rope Breakage
ISHR35	3.50	Pre-streching	Orange	803.30	1.5	535.53	Rope Breakage
ISH50	5.00	Pre-streching	Green	1576.45	1.5	1050.97	Rope Breakage
ISHR50	5.00	Pre-streching	Green	1423.50	1.5	949.00	Rope Breakage

Istanbul , 10.08.2026

Certifier for Product of TÜV NORD
Turkey Teknik Kontrol ve Belgelendirme
A.Ş.

MEHMET SELÇUK

TÜVNORD

TÜV NORD Turkey Tek. Kont. ve Belg. A.Ş.

TÜV NORD Turkey Teknik Kontrol ve
Belgelendirme A.Ş.
Şehit Mehmet Fatih Öngül Sokak, No: 5
Kat: 4 Odak Plaza, Kozyatağı, 34742
Kadıköy/İSTANBUL

Tel. +90-(0) 216 361 29 95
Fax +90-(0) 216 380 67 87
e-mail tuv-nord@tuv-turkey.com